

Map ID  
Direction  
Distance  
Elevation

MAP FINDINGS

EDR ID Number  
EPA ID Number

981  
ESE  
> 1  
1.291 mi.  
6818 ft.

EARTHEN SUMP IN MANHOLE # 62612  
BRIGHTWATER AVENUE NEAR 14 STREET  
BROOKLYN, NY

NY Spills S109059306  
N/A

Relative:  
Higher

Actual:  
7 ft.

SPILLS:

Name: EARTHEN SUMP IN MANHOLE # 62612  
Address: BRIGHTWATER AVENUE NEAR 14 STREET  
City,State,Zip: BROOKLYN, NY  
Spill Number/Closed Date: 0711708 / 2008-03-20  
Facility ID: 0711708  
Facility Type: ER  
DER Facility ID: 342849  
Site ID: 393229  
DEC Region: 2  
Spill Cause: Equipment Failure  
Spill Class: C4  
SWIS: 2401  
Spill Date: 2008-02-06  
Investigator: gdbreen  
Referred To: Not reported  
  
Reported to Dept: 2008-02-06  
CID: 444  
Water Affected: Not reported  
Spill Source: Commercial/Industrial  
Spill Notifier: Responsible Party  
Cleanup Ceased: Not reported  
Cleanup Meets Std: False  
Last Inspection: Not reported  
Recommended Penalty: False  
UST Trust: Not reported  
Remediation Phase: 0  
Date Entered In Computer: 2008-02-06  
Spill Record Last Update: 2008-03-20  
Spiller Name: ERTSDESK  
Spiller Company: CON EDISON MH # 62612  
Spiller Address: BRIGHTWATER AVE  
Spiller Company: 999  
Contact Name: ERTSDESK  
DEC Memo: "03/20/08 - See eDocs for Con Ed report detailing cleanup and closure. 209769. see eDocs"  
  
Remarks: "EARTHEN SUMP FOUND LESS THEN 1 OUNCE; 209769"

All Materials:

Site ID: 393229  
Operable Unit ID: 1150197  
Operable Unit: 01  
Material ID: 2140785  
Material Code: 0541A  
Material Name: dielectric fluid  
Case No.: Not reported  
Material FA: Petroleum  
Quantity: .00  
Units: G  
Recovered: .00  
Oxygenate: Not reported